

Altitude Correction For the Sensible and Latent Heat Equations ACF = 1.0 – 0.0000308 X Feet			
Altitude (Ft)	ACF	Altitude (Ft)	ACF
Sea Level	1.00	6,000	0.82
1,000	0.97	7,000	0.78
2,000	0.94	8,000	0.75
3,000	0.91	9,000	0.72
4,000	0.88	10,000	0.69
5,000	0.85	12,000	0.63
Specific heat of air approximately 0.24 BTU per pound. Latent heat of condensation = 1,076 BTUH per pound.			

Table 10A

Enthalpy in BTU per Pound of Dry Air

Wet Bulb Temperature F	Tenths of a Degree F									
	0.0	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
35	13.01	13.05	13.10	13.14	13.18	13.23	13.27	13.31	13.35	13.40
36	13.44	13.48	13.53	13.57	13.61	13.66	13.70	13.75	13.79	13.83
37	13.87	13.91	13.96	14.00	14.05	14.09	14.14	14.18	14.23	14.27
38	14.32	14.37	14.41	14.46	14.50	14.55	14.59	14.64	14.68	14.73
39	14.77	14.82	14.86	14.91	14.95	15.00	15.05	15.09	15.14	15.18
40	15.23	15.28	15.32	15.37	15.42	15.46	15.51	15.56	15.60	15.65
41	15.70	15.75	15.80	15.84	15.89	15.94	15.99	16.03	16.08	16.13
42	16.17	16.22	16.27	16.32	16.36	16.41	16.46	16.51	16.56	16.61
43	16.66	16.71	16.76	16.81	16.86	16.91	16.96	17.00	17.05	17.10
44	17.15	17.20	17.25	17.30	17.35	17.40	17.45	17.50	17.55	17.60
45	17.65	17.70	17.75	17.80	17.85	17.91	17.96	18.01	18.06	18.11
46	18.16	18.21	18.26	18.32	18.37	18.42	18.47	18.52	18.58	18.63
47	18.68	18.73	18.79	18.84	18.89	18.95	19.00	19.05	19.10	19.16
48	19.21	19.26	19.32	19.37	19.43	19.48	19.53	19.59	19.64	19.70
49	19.75	19.81	19.86	19.92	19.97	20.03	20.08	20.14	20.19	20.25
50	20.30	20.36	20.41	20.47	20.52	20.58	20.64	20.69	20.75	20.80
51	20.86	20.92	20.97	21.03	21.09	21.15	21.20	21.26	21.32	21.38
52	21.44	21.50	21.56	21.62	21.67	21.73	21.79	21.85	21.91	21.97
53	22.02	22.08	22.14	22.20	22.26	22.32	22.38	22.44	22.50	22.56
54	22.62	22.68	22.74	22.80	22.86	22.92	22.98	23.04	23.10	23.16
55	23.22	23.28	23.34	23.41	23.47	23.53	23.59	23.65	23.72	23.78
56	23.84	23.90	23.97	24.03	24.10	24.16	24.22	24.29	24.35	24.42
57	24.48	24.54	24.61	24.67	24.74	24.80	24.86	24.93	24.99	25.06
58	25.12	25.19	25.25	25.32	25.38	25.45	25.52	25.58	25.65	25.71
59	25.78	25.85	25.92	25.98	26.05	26.12	26.19	26.26	26.32	26.39
60	26.46	26.53	26.60	26.67	26.74	26.81	26.87	26.94	27.01	27.08
61	27.15	27.22	27.29	27.36	27.43	27.50	27.57	27.64	27.71	27.78
62	27.85	27.92	27.99	28.07	28.14	28.21	28.28	28.35	28.43	28.50
63	28.57	28.64	28.72	28.79	28.87	28.94	29.01	29.09	29.16	29.24
64	29.31	29.39	29.46	29.54	29.61	29.69	29.76	29.84	29.91	29.99
65	30.06	30.14	30.21	30.29	30.37	30.45	30.52	30.60	30.68	30.75
66	30.83	30.91	30.99	31.07	31.15	31.23	31.30	31.38	31.46	31.54
67	31.62	31.70	31.78	31.86	31.94	32.02	32.10	32.18	32.26	32.34
68	32.42	32.50	32.59	32.67	32.75	32.84	32.92	33.00	33.08	33.17
69	33.25	33.33	33.42	33.50	33.59	33.67	33.75	33.84	33.92	34.01
70	34.09	34.18	34.26	34.35	34.43	34.52	34.61	34.69	34.78	34.86
71	34.95	35.04	35.13	35.21	35.30	35.39	35.48	35.57	35.65	35.74
72	35.83	35.92	36.01	36.10	36.19	36.29	36.38	36.47	36.56	36.65
73	36.74	36.83	36.92	37.02	37.11	37.20	37.29	37.38	37.48	37.57
74	37.66	37.76	37.85	37.95	38.04	38.14	38.23	38.33	38.42	38.52
75	38.61	38.71	38.80	38.90	38.99	39.09	39.19	39.28	39.38	39.47
76	39.57	39.67	39.77	39.87	39.97	40.07	40.17	40.27	40.37	40.47
77	40.57	40.67	40.77	40.87	40.97	41.08	41.18	41.28	41.38	41.48
78	41.58	41.68	41.79	41.89	42.00	42.10	42.20	42.31	42.41	42.52
79	42.62	42.73	42.83	42.94	43.05	43.16	43.26	43.37	43.48	43.58
80	43.69	43.80	43.91	44.02	44.13	44.24	44.34	44.45	44.56	44.67
81	44.78	44.89	45.00	45.12	45.23	45.34	45.45	45.56	45.68	45.79
82	45.90	46.01	46.13	46.24	46.36	46.47	46.58	46.70	46.81	46.93
83	47.04	47.16	47.28	47.39	47.51	47.63	47.75	47.87	47.98	48.10
84	48.22	48.34	48.46	48.58	48.70	48.83	48.95	49.07	49.19	49.31
85	49.43	49.55	49.68	49.80	49.92	50.05	50.17	50.29	50.41	50.54

Interpolated to tenths of degrees from 1963 edition ASHRAE Guide and Data Book. Published by the American Heating, Refrigerating and Air Conditioning Engineers, Inc. Society